

Operations Office:
Appalachian Utilities, Inc.
1674 Park Avenue
Lock Haven, PA 17745
Tel: 570-769-7647
Fax: 570-769-7654

Billing Office:
Appalachian Utilities, Inc.
P.O. Box 248
Waymart, PA 18472
Tel: 570-769-7644
Fax: 866-355-9483

Account No: _____
Meter No: _____
Ball Valve: _____ **Check Valve:** _____
MIU No.: _____
Approved By: _____
Date: _____

APPLICATION FOR WATER SERVICE

Modified November 20, 2015

Circle Occupant Status: **OWNER** **TENANT** **Date:** _____

(Please Print) SERVICE ADDRESS – PHYSICAL ADDRESS OF PREMISES TO BE SERVED:

Applicant's Name and Email: _____

Street Address: _____

City: _____ State: _____ Zip Code: _____

Date of Birth: _____ Social Security # _____ - _____ - _____ Driver's License # _____

Telephone No. (REQUIRED): _____ Mobile No. _____

(Please Print) BILLING ADDRESS – ADDRESS THAT BILLS ARE TO BE MAILED TO:

_____ Initial if same as Service Address. _____ Initial if you are the owner of the Service Address

Applicant's Name(s): _____

Street Address: _____

City: _____ State: _____ Zip Code: _____

TYPE OF HEAT ON PREMISES (REQUIRED, CHECK ONE):

- _____ Circulating Hot Water
- _____ Forced Hot Air
- _____ Steam
- _____ Heat Pump
- _____ Electric
- _____ Wood or Coal Stove
- _____ Other (PLEASE EXPLAIN) _____

Applicants place of employment: _____

Work Telephone No.: _____

Does this premises have water service now? YES _____ NO _____

Date ready for water service: _____ Date of closing: _____

Former Occupant's name(s): _____

Size of service line: _____ Type of service line: _____

APPALACHIAN UTILITIES, INC.
APPLICATION FOR WATER SERVICE

I/We hereby agree to, and to be legally bound by, the following Rules, Regulations and Specifications regarding water service.

1. A written application must be signed by the property owner(s) prior to start of any water service line excavation or construction.
2. The signature on the application must be exactly the same as appears on the current property deed.
3. The signed application must be on file at the Water Company office prior to starting water service.
4. A Water Company representative must mark location of the water service line prior to any excavation.
5. Water service will not be furnished if any of these Rules & Regulations are not adhered to.
6. The water service line shall be located up hill above and at a distance of 18", and in a separate trench from any sewage facility or part thereof. Extreme caution shall be taken that no sewage infiltrates the water trench.
7. Bury depth must be at least 48" deep. The trench bottom must be flat and free of sharp rocks or objects.
8. No other utility service may be laid in the same trench.
9. Water service lines shall be at least ¾" in diameter and shall be "K" type copper tubing. No plastic pipe is allowed.
10. All fittings shall be compression type as manufactured by Mueller Co. or Ford. No solder joints allowed.
11. Allowance for expansion and contraction shall be at the rate of 6" per 100 feet. Snaking the pipe through the trench is sufficient.
12. All work must be inspected and tested by a Water Company representative prior to any backfill. The customer is responsible to request appointments for the location, inspection, test, etc.
13. The pipe shall be blown free of dirt and foreign objects; and, pressure test performed in the presence of the water company representative prior to backfill.
14. The service shall be bedded in 6" of sand with at least 6" of sand for cover. The sand used shall be free of any and all rocks, stones or any sharp objects.
15. Selected material containing no large rocks shall be used to complete the backfill.
16. After January 6, 1991, by order of PA DEP, all customers requesting connection to the system must certify to the Water Company that only lead-free materials were used in the plumbing of the building. Without proper certification, the Water Company must refuse connection.
17. It shall be the owner's obligation to inform the plumber or contractor, or the responsible party of these Rules, Regulations and Specifications.
18. Any falsification of records, tampering with company equipment, negligence, or failure to pay water rent may result in service termination until restitution or correction is made.
19. **TARIFF RULES AND REGULATIONS SEC. 5-5.3:**
The customer shall be responsible to the utility at all times for proper protection of the meter for injury or loss of the meter arising out of or caused by customer's negligence or carelessness; or, that of his servants, agents, employees or any other person upon his/her premises, under or by authority of his consent, or sufferance. The customer shall permit no one who is not an agent of the utility or otherwise lawfully authorized so to do, to remove, inspect, or tamper with the utility's meter or other property of the utility on his premises.
20. Unless otherwise authorized by the Commission, a public utility furnishing metered service shall provide, installed at its own expense; and continue to own, maintain and operate all meters. The customer, however, shall properly protect the meter from damage by frost or other cause and shall be held responsible for repairs or replacement of the meter made necessary by the customer. Each utility seeking to impose responsibility for the damage to the meter caused by negligence of the customer or intentional act shall first provide each customer with notice explaining the proper maintenance that should be given to the meter. The notice shall be included on the "Rules & Regulations" of the utility.
21. A PA DEP approved backflow device must be installed downstream of the water meter in order to pass inspection.
22. The customer must have a ball valve and double check valve installed. The absence of either is grounds for a 10 Day Service Termination Notice. The check valve is required to comply with the Safe Drinking Water Act of 1974.

I HAVE READ AND UNDERSTAND THESE RULES AND REGULATIONS FOR WATER SERVICE:

DATE: _____ APPLICANT'S SIGNATURE: _____